CERTIFICATE OF COMPLIANCE

Certificate Number: **SGSNA/26/GZ/00321X**

Contract Number: 801593
Certificate Project Number: GZ-CERT260603231

Certified Product: Power Station (AC ESS)
Trademarks:

Model(s): EF-TT-5P*6-G1, EF-TT-5*6-G1
Technical Data: See Page 2 and 3

Certificate Holder: EcoFlow Inc.
Room 401, Plant #1, Runheng Industrial Zone, Fuyuanyi Road, Zhancheng Community, Fuhai Street, Bao'an, Shenzhen, Guangdong, China

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. This product has been certified in accordance with ISO/IEC 17065:2012, Conformity assessment — Requirements for bodies certifying products, processes and services and under the Type 3 guidelines provided in ISO/IEC 17067:2013, Conformity assessment — Fundamentals of product certification, and in accordance with:

ANSI/CAN/UL 9540:2023,Third Edition, Dated June 28, 2023

Certification Condition

Both models are to be installed in accordance with the National Electrical Code NFPA 70 (National Electric Code or CSA C22.1 (Canadian Electric Code) and Installation of Stationary Energy Storage Systems, NFPA 855 by end user.

Authorized by:

Jason Wei
Certifier

Effective date: 14 August 2026

SGS operates certification programs under the authority of several accreditation or recognition bodies including A2LA, OSHA NRTL, and Standards Council of Canada. This certificate is issued by the company under its General Conditions for Certification Services accessible at https://www.sgs.com/en/terms-and-conditions. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

CERTIFICATE OF COMPLIANCE

Certificate Number: **SGSNA/26/GZ/00321X**

Contract Number: 801593
Certificate Project Number: GZ-CERT260603231

Technical Data:

Model: EF-TT-5P*6-G1

AC Input: 100 – 120 VAC, 50/60 Hz, 15 A (Duration time < 3h when current exceeds 12A)

AC Power IN/OUT port input: (Bypass mode): 100/200 – 120/240 V~ (Split phase), 208V(Single-phase (L-L), 120°), 50/60 Hz, 41.7 A Max.

AC Power IN/OUT port input (Charge mode): 100/200 – 120/240 V~ (Split phase), 208V(Single-phase (L-L), 120°), 50/60 Hz, 7660 W Max.

Max. Input Voltage: 450 VDC

MPPT rating: 40 – 450 VDC, 16 A, 4000 W Max.

Total Output: 10 kW Max.

AC Output: 10 kW Max, (7200W for discharge only) 120 V~, 60 Hz, 20 A (x2) Max. per port, 120/240 V~, 60 Hz, 41.7 A(×1) Max. per port

AC Output (Bypass MODE):

10 kW Max, 100 – 120 V~, 50/60 Hz, 20 A (×2) Max. per port,

100/200-120/240V~ (Split phase), 208V(Single-phase (L-L), 120°),

50/60 Hz, 41.7 A (×1) Max. per port

AC Power IN/OUT Port Output:

10 kW Max, (7200W for discharge only) 120/240 V~ (Split phase),

208V(Single-phase (L-L), 120°), 60 Hz, 41.7A Max.

Charge Temperature (ambient): 0 - 45°C (32 - 113°F)

Discharge Temperature (ambient): -10 - 45°C (14 - 113°F)

Capacity: 5017.6 Wh, 204.8 VDC, 24.5 Ah

Max. Energy storage capacity: 30105.6Wh

SGS operates certification programs under the authority of several accreditation or recognition bodies including A2LA, OSHA NRTL, and Standards Council of Canada. This certificate is issued by the company under its General Conditions for Certification Services accessible at https://www.sgs.com/en/terms-and-conditions. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

CERTIFICATE OF COMPLIANCE

Certificate Number: **SGSNA/26/GZ/00321X**

Contract Number: 801593
Certificate Project Number: GZ-CERT260603231

Technical Data:

Model: EF-TT-5*6-G1

AC Input: 100 – 120 VAC, 50/60 Hz, 15 A (Duration time < 3h when current exceeds 12A)
AC Power IN/OUT port input: 100/200 – 120/240 V~ (Split phase), 208V(Single-phase (L-L), 120°), 50/60 Hz, 30 A Max.
Max. Input Voltage: 450 VDC
MPPT rating: 40 – 450 VDC, 16 A, 4000 W Max.
Total Output: 7200 W Max.
AC Output (Discharge Only): 7200 W Max. 120 V~, 60 Hz, 20 A (x3) Max. per port. 120/240 V~, 60 Hz, 30 A (x1) Max. per port
AC Output (Bypass MODE):
7200W Max., 100 – 120 V~, 50/60 Hz, 20 A (x3) Max. per port.
100/200 – 120/240 V~ (Split phase), 208V(Single-phase (L-L), 120°), 50/60 Hz, 30A (x1) Max. per port
AC Power IN/OUT Port Output (Discharge Only):
7200W Max., 120/240 V~ (Split phase), 208V(Single-phase (L-L), 120°), 60 Hz, 30 A Max.
USB-A Fast Charge Output: 5VDC, 3A; 9VDC, 2A, 12VDC, 1.5A, 18W;
USB-C Output: 5VDC, 3A; 9VDC, 3A; 12VDC, 3A; 15VDC, 3A;
20VDC, 3A; 60W;
Charge Temperature (ambient): 0- 45°C (32 - 113°F)
Discharge Temperature (ambient): -10 - 45°C (14 - 113°F)
Capacity: 5017.6Wh, 204.8VDC, 24.5Ah
Max. Energy storage capacity: 30105.6Wh

SGS operates certification programs under the authority of several accreditation or recognition bodies including A2LA, OSHA NRTL, and Standards Council of Canada. This certificate is issued by the company under its General Conditions for Certification Services accessible at https://www.sgs.com/en/terms-and-conditions. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com